



# NCBFO

## Oct 6, 2022

### Ottawa, Ontario

Control Valve Technology  
What Cx Agents Should Know  
Rick Mohammed, Regional Application Consultant



# Learning Objectives

---

## **Pressure Independent Valves and the Energy Valve**

- What is a pressure independent valve and why do we need it
- Reading valve position, Flow, BTU's, coil water inlet and outlet temperature
- On board Cx report

## **6 Way Pressure Independent Valves**

- What is a 6 way valve and where is it used
- Verify max flow settings for heating and cooling
- Measure flow
- Cycle valve

## **Butterfly Valves**


- The BFV has become a lot more transparent
- Verify valve position, run time, auxiliary switch setting

## **Thermal (BTU) Meter**

- On board commissioning and report generation

# What is a Pressure Independent Valve

A control valve that is dynamically pressure independent through the full range of control. Control Valve and balancing in one unit.



# CONTROL VALVE OVERFLOW

---

$$C_v = \frac{GPM}{\sqrt{\Delta P}}$$

**At Design**

$$C_v = \frac{100GPM}{\sqrt{4}}$$

$$C_v = 50$$

**During Operation**

$$C_v = \frac{100GPM}{\sqrt{10}}$$

$$C_v = 32$$

If the pressure drop changes the flow changes



# CONTROL VALVE OVERFLOW

---

Only 6 PSI Increase

$$\begin{aligned}GPM &= C_v * \sqrt{4} \\ &= 50 * 2 \\ &= 100GPM\end{aligned}$$

$$\begin{aligned}GPM &= C_v * \sqrt{10} \\ &= 50 * 3.162 \\ &= 158GPM\end{aligned}$$

58% Increase In Flow

If the pressure drop changes the flow changes

# Flow Verification




Pressure ports  
5 psi minimum

Balancing at full load !!!!  
only

# Flow Verification





Valve Model 1/2"	Clip Position for Flow Adjustment (GPM)																			
	1	1+	2-	2	2+	3-	3	3+	4-	4	4+	5-	5	5+	6-	6	6+	N-	N	No Clip
Z2050QPT-B			0.1					0.2			0.3		0.4		0.5		0.6	0.7	0.8	0.9
Z2050QPT-D	0.2			0.3			0.4	0.5		0.6	0.7	0.8	0.9	1.0	1.2	1.3	1.5	1.6	1.8	2.0
Z2050QPT-F				0.6		0.7	0.8	0.9	1.0	1.3	1.5	1.7	1.9	2.2	2.5	2.8	3.1	3.3	3.6	4.3
<b>Valve Model 3/4"</b>																				
Z2075QPT-G			1.6	1.8	2.1	2.4	2.7	3.0	3.3	3.7	4.0	4.4	4.9	5.3	5.8	6.3	6.7	7.2	7.7	9.0
Runtime	30	33	35	37	39	41	43	45	47	49	51	53	55	58	60	62	64	66	68	75



# Flow Verification



# Flow Verification



# Flow Verification

**PIQCV**

Valve Model 1/2"	Clip Position for Flow Adjustment (GPM)																			
	1	1+	2-	2	2+	3-	3	3+	4-	4	4+	5-	5	5+	6-	6	6+	N-	N	No Clip
Z2050QPT-B			0.1					0.2			0.3		0.4		0.5		0.6	0.7	0.8	0.9
Z2050QPT-D	0.2			0.3			0.4	0.5		0.6	0.7	0.8	0.9	1.0	1.2	1.3	1.5	1.6	1.8	2.0
Z2050QPT-F				0.6		0.7	0.8	0.9	1.0	1.3	1.5	1.7	1.9	2.2	2.5	2.8	3.1	3.3	3.6	4.3
<b>Valve Model 3/4"</b>																				
Z2075QPT-G			1.6	1.8	2.1	2.4	2.7	3.0	3.3	3.7	4.0	4.4	4.9	5.3	5.8	6.3	6.7	7.2	7.7	9.0
Runtime	30	33	35	37	39	41	43	45	47	49	51	53	55	58	60	62	64	66	68	75

# Flow Verification





# Electronic PI, Flow Readings

Ultrasonic Flow  
Meter








# Control Valve with BTU Meter

$$\text{Flow} \times \Delta T \times 500 = \text{BTU/h}$$

Glycol Compensation

Ultrasonic Flow Meter




Temperature Sensors



Tonnage drops by 50% and second chiller is needed to make up loss. The problem gets worse with increase in load until all chillers are operating excessively

### Primary/Secondary Loop 3 Chillers and 3 AHU's


Delta T of chiller drops to 6 degrees



Delta T design is 12 degrees, therefore a return water temperature of 54 deg F will provide rated chiller tonnage, but pressures are always different at each AHU causing higher flows than expected, and colder return water.

# The Solution

Chiller capacity is restored



Install Energy Valves

Return water Temperature and Delta T is restored

Remove 2 way valves and open balancing valves fully



# On Board Commissioning

## Commissioning / Status Report Belimo Energy Valve

Device Mp Serial Number	22142-30002-022-168
-------------------------	---------------------

Protocol creation date/time	20.01.2022 / 15:03
-----------------------------	--------------------

Project Name	Project Name
--------------	--------------

Address	33 Turner Road, 06810 Danbury
---------	----------------------------------

Installation Location	Second Floor Outside Employee Lounge
-----------------------	--------------------------------------

Device Name	Energy Valve
-------------	--------------

Device Type	EV125+AKRX-E
-------------	--------------

### Application Settings

Valve Type	2way
------------	------

Nominal Pipe Size	1 1/4"   DN32
-------------------	---------------

Nominal Flow	28.50 gpm
--------------	-----------

Media	Propylene Glycol
-------	------------------

Glycol Concentration	28.31 %
----------------------	---------

Maximum Flow	28.50 gpm
--------------	-----------

Maximum Power	1300.00 kBTU/h
---------------	----------------

Control Mode	Position control
--------------	------------------

Setpoint Source	Analog
-----------------	--------

Control Signal Range (Y3)	2-10V
---------------------------	-------

Invert Control Signal Range (Y3)	inverted
----------------------------------	----------

Analog Feedback (U5)	Relative flow
----------------------	---------------

Analog Feedback Range	2-10V
-----------------------	-------

### IP Settings

MAC Address	50:2d:f4:0f:e1:f1
-------------	-------------------

IP Host Address	10.200.8.191
-----------------	--------------

IP Mode	Static
---------	--------

Network Mask	255.255.255.0
--------------	---------------

Gateway	10.200.8.2
---------	------------

Broadcast Address	10.200.8.255
-------------------	--------------

### Communication Settings

Bus Protocol	BACnet IP
--------------	-----------

### BACnet IP Settings

Port	47808
------	-------

Device Setting	Simple device
----------------	---------------

### Device Object Settings

Instance ID	3043
-------------	------

Device Name	Energy Valve
-------------	--------------

BACnet Location	Device Location
-----------------	-----------------

System Status	Operational
---------------	-------------

Protocol Version	1
------------------	---

Protocol Revision	14
-------------------	----

### Version Information

BSP Version	13.9.0
-------------	--------

CSP Version	4.21.1
-------------	--------

Application Model	EV4
-------------------	-----

Application Version	1.0.4
---------------------	-------

### Live Values

Forced Control	None
----------------	------

Valve Position	99.33 %
----------------	---------

Actuator Sync Position	Sync at 0%
------------------------	------------

Flow	9.22 gpm
------	----------

External Temperature Sensor (T1)	73.18 °F
----------------------------------	----------

Integrated Temperature Sensor (T2)	72.33 °F
------------------------------------	----------

Heating Energy	1006.32 kBTU
----------------	--------------

Cooling Energy	11549.75 kBTU
----------------	---------------

Total Volume	1425.16 m3
--------------	------------

Delta T Manager Status	not selected
------------------------	--------------

### Delta T Manager

dT Limiting Function	Off
----------------------	-----

dT Limiting Value	9.99 °F
-------------------	---------

### Health State

Health State	OK
--------------	----




# 6 Way Valve



- $\frac{1}{2}$ ,  $\frac{3}{4}$ , and 1.0 inch
- Different Cv options for heating and cooling

Replace 4, 2 way valves with one 6 way

Only one controls point required




1 valve instead of 4  
1 BAS connection instead of 4

Estimated cost savings \$1800 per FCU or Chilled Beam 1/2 inch

# Collecting Information Using NFC



# Set Up Using Near Field Communication





# Set Up Using Near Field Communication




# Butterfly Valve



# Torque Sensing for Tight Shut Off



Break Away Torque



# Torque Sensing for Tight Shut Off






- Auto Set up
- Self Adjusting Valve Seating Senses Break Torque
- As seat wears, torque is applied for tight shut off, not valve position.




# Commissioning BFV's



Values & Settings	Factory Setting	Manual	Power On 	Power Off 	Power On 
Running time setting [30-120 s]	35 s	-	RW	RW	RW
Max angle of rotation	100%	-	RW	RW	RW
Actuator Position [0-100%]	-	Position Indicator	R	-	R
Setting for auxiliary switch s2 [0-90°]	85%	Hand crank	-	-	-
Display of input signal voltage (Power supply)	-	-	R	-	-
Valve Setting [Regular, 8", 10", 12"]	Type specific	-	RW	RW	-
Override Control (Force Position)	-	Hand crank	RW	-	RW
Location String	-	-	RW	RW	-
Control [Floating Point, On/Off, 0.5 - 10V, 2 - 10V, 4 - 20 mA]	2..10V	-	RW	RW	RW
Feedback Mode [2 - 10V, 0.5 - 10V, inverted]	2..10V	-	RW	RW	RW
Feedback Mode [DC variable]	-	-	-	-	RW
Control Signal [DC variable]	-	-	-	-	RW
Control Signal Fail Position [None, On/Off]	None	-	RW	RW	-
Hybrid Mode - Setpoint [MP-Bus, Analog]	Bus	-	RW	RW	-
Bus Setting [MP-Bus, BACnet]	MP, PP	-	RW	RW	-
Power Off Position [0 - 100%]	0%	-	RW	RW	RW
Power Fail Delay [0 - 10 s]	2 s	-	RW	RW	RW

[R=reading; W=writing]

# Thermal Energy Meter



- On Board Commissioning
- NFC
- Glycol Compensation



## Commissioning / Status Report Thermal Energy Meter

Configuration Date / Time	21.01.2022 / 13:09 UTC
Project Name	Project Name
Address	
Zip Code	
City Name	
Device Name	Thermal Energy Meter
Serial Number	22141-40003-034-087
Installation Location	Belimo Canada
Device Type	

### Application Settings

DN Size	1/2"   DN 15
qp	1.5 m3/h
Medium	Water
Glycol Concentration	0 %
Feedback Signal	Power
Feedback Signal Range	0...10 V

### IP Settings

MAC Address	50:2d:f4:1d:84:53
IP Address	192.168.0.10
IP Configuration	Static/Zeroconf
Network Mask	255.255.255.0
Gateway	0.0.0.0
Broadcast Address	192.168.0.255



### Communication Settings

Bus Protocol	BACnet MS/TP
--------------	--------------

### BACnet MSTP Settings

Baud Rate	38400
BACnet/Modbus Address	1
Terminating Resistor	false

### Device Object Settings

Instance ID	1
BACnet Device Name	Thermal Energy Meter
BACnet FW Revision	14.10.0001

### Live Values

Volumetric Flow	0 m3/h
External Temperature Sensor (T1)	20.87 °C
Integrated Temperature Sensor (T2)	21.51 °C
Heating Energy	0 J
Cooling Energy	0 J
Total Volume	0 m3

### Health State

Collective Error Status	Error
-------------------------	-------

### Product Information

Operating System Version	13.9.0
Core Software Version	4.21.1
Model Name	TEM4
Model Version	1.0.4

## Lots of data easily accessed

- ZTH
- NFC (Near Field Communication)
- Commissioning Reports





**2022 NCBFO**  
**Ottawa, ON**  
**October 6, 2022**

**Rick Mohammed**  
Regional Application Consultant

